

**BELMONT COUNTY COMMISSION**  
**Belmont County Water and Sewer District**

**Ohio Valley Mall Sewage Lift Station Replacement**  
**Addendum No. 4**

**December 11, 2020**

**TO ALL BIDDERS**

1. The bid opening has been rescheduled for Wednesday December 23, 2020 at 11:00 AM.
2. The engineer's estimate for the following projects is \$1,800,000:
  - Wastewater Transmission System Upgrade
  - Mall Lift Station Replacement
  - Summerhill Lift Station
3. Document 00410 Bid Form:
  - a. Delete Item N of Article 7, Paragraph 7.01
4. Drawing 8 Door Details: Revise the door from insulated aluminum to insulated steel door. Color shall be standard Dark Bronze or similar color to match roofing system.
5. Drawing 6 HV-1 and HV-2: Color shall be manufacturer's standard aluminum color.
6. Drawing 5: Color of metal roofing, gutters, downspouts, fascia, and flashing shall be standard Dark Bronze or similar color.
7. Drawing 1r: Manholes A1-A4 do not require lining (Section 03655). Per Drawing 4 Gravity Sewer Tie-in Detail, only the existing lift station wet well shall be cleaned and lined.

END OF ADDENDUM NO. 4

VAUGHN, COAST, & VAUGHN, INC.



---

Jeffrey A. Vaughn, P.E.