

**BELMONT COUNTY COMMISSION
Belmont County Water and Sewer District**

**Contract No. 1 -
Fox Shannon Wastewater Treatment Plant Improvements**

Addendum No. 5

December 11, 2020

TO ALL BIDDERS

1. The bid opening has been rescheduled for Wednesday December 23, 2020 at 11:00 AM.
2. The engineer's estimate for this project is \$8,000,000.
3. Document 00410 Bid Form
 - a. Delete Item N of Article 7, Paragraph 7.01
4. Specification Section 03371 Shotcrete Concrete Rehabilitation
 - a. The following company has been contacted regarding the ability to perform the work identified in this contract. This company will visit the site next week to review the application and prepare a scope of work and price for all Bidders. The Bidder may use any qualified firm to perform this type of work.

Sofis Company Inc.
554 Bocktown Cork Rd.
Clinton, PA 15026
Attn: Ted Sofis
[724-378-2670](tel:724-378-2670)
tsofis@sofiscompany.com
5. Specification Section 11357 Ultraviolet Disinfection Equipment
 - a. Delete paragraph 2.16 Cleaning System
 - b. Delete lines 2.15A.1.f and 2.15A.2.a.ii that reference cleaning motor.
6. Specification Section 13208 Glass Coated Bolted Steel Sludge Holding Tanks
 - a. Replace paragraph 2.06 J with the following:

Supernatant Decanter System: Stainless steel T-shaped floating decanter with foam-filled float with ballast to allow lowering and raising decanter in water as required; no submerged valves or seals; base hinge to provide 180 degrees of decanter travel; mounted as indicated on CONSTRUCTION DRAWINGS; Fluidyne *Stainless Steel Floating Decanter*, or equal. Tank manufacturer shall design and provide a bottom support/stop arrangement for the decanter to rest on when it is approximately horizontal, preventing it from setting on the diffuser grid. The support shall consist generally of a vertical steel pipe with steel plate welded to the bottom of the pipe for mounting to the tank concrete floor. The top of the steel pipe shall have a similar steel plate welded to it for the decanter to rest on. The support assembly shall be galvanized and coated for immersion service.

END OF ADDENDUM NO. 5

VAUGHN, COAST, & VAUGHN, INC.



Jeffrey A. Vaughn, P.E.